

EU SEER/SCOP Test

欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准:		<input checked="" type="checkbox"/> (EU) No 626/2011	<input checked="" type="checkbox"/> (EU) No 206/2012	<input checked="" type="checkbox"/> EN14825	<input checked="" type="checkbox"/> EN 14511	<input checked="" type="checkbox"/> ENV 12102	<input checked="" type="checkbox"/> Other _____										
GPA requirement: 产品审批要求: <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"> GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%)</td> <td style="width: 20%; text-align: center; padding: 5px;">>=100%</td> <td style="width: 50%;"> GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%)</td> <td style="width: 20%; text-align: center; padding: 5px;">>=100%</td> </tr> <tr> <td></td> <td></td> <td style="text-align: center; padding: 5px;">GPA requirement for Sound Power GPA 的声功率要求</td> <td style="text-align: center; padding: 5px;"><=Rated</td> </tr> </table>										GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%)	>=100%	GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%)	>=100%			GPA requirement for Sound Power GPA 的声功率要求	<=Rated
GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%)	>=100%	GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%)	>=100%														
		GPA requirement for Sound Power GPA 的声功率要求	<=Rated														
<input checked="" type="checkbox"/> Inverter Single Split type 变频一拖一 分体机 <input type="checkbox"/> On/off Single Split type 定速一拖一 分体机 <input type="checkbox"/> Inverter Multisplit type 变频一拖多 分体机 <input type="checkbox"/> On/off Multisplit type 定速一拖多 分体机																	
ERP Hisense Mode: 欧洲海信型号:		AUV140UR4RC8&AUV140U6RW8			Manufacturer Model: 工厂型号:		AUV-48UR4RC8&AUV-48U6RW8										
Test Result:																	
Function (indicate to which function information applies)					If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.												
Cooling	Y				Average (mandatory)	Y											
Heating	Y				Warmer (if designated)	Y											
					Colder (if designated)	N											
Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit								
Design load					Seasonal efficiency												
cooling	Pdesignc	13.50	13.500	kW	cooling	SEER	6.40	6.43	—								
heating/Average	Pdesignh	9.00	9.000	kW	heating/Average	SCOP(A)	4.40	4.43	—								
heating/Warmer	Pdesignh	9.00	9.000	kW	heating/Warmer	SCOP(W)	5.40	5.44	—								
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—								
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj												
Tj = 35 °C	Pdc	13.50	13.530	kW	Tj = 35 °C	EERd	3.21	3.25	—								
Tj = 30 °C	Pdc	9.99	10.020	kW	Tj = 30 °C	EERd	4.90	4.92	—								
Tj = 25 °C	Pdc	6.35	6.400	kW	Tj = 25 °C	EERd	6.87	6.90	—								
Tj = 20 °C	Pdc	2.90	2.960	kW	Tj = 20 °C	EERd	11.15	11.22	—								
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj												
Tj = -7 °C	Pdh	7.92	7.970	kW	Tj = -7 °C	COPd	3.02	3.06	—								
Tj = 2 °C	Pdh	4.86	4.880	kW	Tj = 2 °C	COPd	4.37	4.40	—								
Tj = 7 °C	Pdh	3.15	3.170	kW	Tj = 7 °C	COPd	5.45	5.48	—								
Tj = 12 °C	Pdh	2.60	2.670	kW	Tj = 12 °C	COPd	6.40	6.44	—								
Tj = bivalent temperature	Pdh	7.92	7.970	kW	Tj = bivalent temperature	COPd	3.02	3.06	—								
Tj = operating limit	Pdh	8.50	8.650	kW	Tj = operating limit	COPd	2.50	2.55	—								
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj												
Tj = 2 °C	Pdh	9.00	9.120	kW	Tj = 2 °C	COPd	2.90	2.93	—								
Tj = 7 °C	Pdh	5.76	5.790	kW	Tj = 7 °C	COPd	5.05	5.08	—								
Tj = 12 °C	Pdh	2.80	2.810	kW	Tj = 12 °C	COPd	6.30	6.37	—								
Tj = bivalent temperature	Pdh	9.00	9.120	kW	Tj = bivalent temperature	COPd	2.90	2.93	—								
Tj = operating limit	Pdh	9.00	9.120	kW	Tj = operating limit	COPd	2.90	2.93	—								
Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj												
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—								
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—								
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—								
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—								
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—								
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—								
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—								
Bivalent temperature					Operating limit temperature												
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C								
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C								

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	P _{CYCC}	NA	NA	kW	cooling	EER _{CYC}	NA	NA	—
heating	P _{CYCH}	NA	NA	kW	heating	COP _{CYC}	NA	NA	—
Degradation co-efficient cooling (**)	C _{DC}	0.25	NA	—	Degradation co-efficient heating (**)	C _{DH}	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.011	0.011	kW	cooling	Q _{CE}	739	735	kWh/a
standby mode	P _{SB}	0.011	0.011	kW	heating/Average	Q _{HE}	2863	2841	kWh/a
thermostat-off mode	P _{TO}	0.001	0.001	kW	heating/Warmer	Q _{HE}	2334	2316	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	71	70.8	dB(A)
					Sound power level (outdoor)	LWA	74	72.1	dB(A)
staged	N				Global warming potential	GWP	675	0.709	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h

TEST CONCLUSION: 测试结论

Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?

Compliant

Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)